



Product Service

# Attestation of Conformity

No. N8 13 05 52840 027

**Holder of Certificate: Samwon Act Co., Ltd.**

25-15, Omgung-Dong, Sasang-Gu

Pusan 617-030

REPUBLIC OF KOREA

**Product:****Programmable Controller  
(Relay Board)**

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2006/95/EC relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive. It refers only to the particular sample submitted for testing and certification. See also notes overleaf.

**Test report no.:**

CPSA01202613

**Date,** 2013-05-16  
( James Jeon )

After preparation of the necessary technical documentation as well as the EC conformity declaration the required CE marking can be affixed on the product. Other relevant directives have to be observed.

Page 1 of 2



Product Service

**Attestation of Conformity****No. N8 13 05 52840 027****Model(s):****R16G-PS5A-F, R16G-NS5A-F, R16G-PS5A-M,  
R16G-NS5A-M, R16G-PS5A-S, R16G-NS5A-S****Parameters:**

Coil:	24 V d.c.
Contacts:	250 V a.c., 5 A 30 V d.c., 5 A
Overvoltage category:	II
Pollution degree:	2
Degree of protection against ingress of liquids:	IP20
Relay Type:	G6B-1174P-FD-US

**Tested  
according to:****EN 61131-2:2007**